

Splaiul Unirii 313, lot 2, parter din constructia P+4, C1-U63 030138, sector 3, Bucuresti - România

031 426 0970 oicpe@oicpe.ro

Nr. RC: J40/3946/2009 CIF: RO25338954

Cont: RO60CARP0452P00633990RO01-Patria Bank RO71TREZ5069XXX011505 - Trezorerie sector 3



LABORATORUL DE ÎNCERCĂRI PENTRU CERTIFICAREA PRODUSELOR ELECTRICE

Testing Laboratory for Electrical Products Certification

accredited for TESTING



RAPORT DE ÎNCERCĂRI TEST REPORT

SR EN ISO/IEC 17025:2018 ACCREDITATION CERTIFICATE LI 911

> No. 167 / 2023.03.14 Page 1 / 20

Exemplar no. 5 from 6

ÎNCERCAREA SOLICITATĂ

Required Test

PRODUSUL

Equipment

PRODUCĂTOR

Manufacturer

CLIENT (nume, adresă, cerere) Customer (name, address, order)

MANAGER LABORATOR

Laboratory Manager

DIRECTOR TEHNIC OICPE
OICPE Technical Director

BIOFEEDBACK SYSTEM type ED.X

Tests according to

QUANTUM MEDICAL S.R.L.

SR EN 60601-1-2:2016 + A1:2021

QUANTUM MEDICAL S.R.L.

61 Miron Costin street, Satu Mare, Romania Order no. 01/ 2023.01.27

UNIVERSAL ELECTROPHYSIOLOGICAL

Eng. Răzvan NEACŞU

Eng. Dragos ROSMETENIUC

Test results refersionly to tested products.

This document may be reproduced only in its entirety.

Rezultatele încercărilor se referă numai la produsele încercate. Acest document poate fi reprodus numai în întregime.





Laboratorul de Încercări pentru Certificarea Produselor Electrice

Page 2/20

Test Report no. 167 / 2023

PRODUCT TECHNICAL DATA: UNIVERSAL ELECTROPHYSIOLOGICAL BIOFEEDBACK SYSTEM type ED.X

The system consists of:

The ED.X module

Power supply Input current

Applied parts Protection degree provided by enclosure

Output channels

Time to change the signal Time to change the channel Rated output current /channel

Output voltage /channel

Output frequency range

Frequency resolution Frequency accuracy

Dimensions (length, width, height)

Operate temperature

The control unit / interface

: BF-type : IP40 : 12

: maximum 300 ms : maximum 100 ms : maximum 1 mA

: 5 V_{dc} (USB port)

: maximum 0,5 A

: 0 ... 4 V : 0 ... 100 kHz (dual channel, sinusoidal)

0 ... 100 kHz (single channel, sinusoidal, 64 points)) 0 ... 25 kHz (single channel, sinusoidal, 256 points)) : 0.01 Hz

: maximum ± 1.5 %

 $: [200 \times 150 \times 60] \text{ mm } \pm 0.5 \text{ mm}$: 10 °C40 °C

: laptop (recommended)

Use (as a universal electrophysiological biofeedback system) for:

- Pain therapy caused by various traumas, through (MENS [microcurrent transcutaneous electro-nerval

- Treatment of neuromuscular dystonia and muscle contractures, muscle tension and/or muscle spasm through muscle re-education (EMG; EEG-based visual-haptic biofeedback)

Serial

: 1EX230103 (ED.X module)

Product type

Date product received

Tests period Sampling

CND137C22J (HP laptop, model 15-dw3043nq) : sample

: 2023.01.30

: 2023.01.30... 2023.03.14

: Unknown The product was presented for tests by the client

: one system

Number of tested products

Eng. Alexandru STANESCU

Ediția din 12.01.2022

LICPE Cod PG-24-F-27R





T		Test Report no. 167 / 2023	Page 3/20 Fulfilling	
	quirement according to Results		the requirement	
	General requirements			
	Risk management process for ME equipment a		- D	
	Risks resulting from reasonably foreseeable electromagnetic disturbances shall be taken into account in the risk management process the electromagnetic environment conditions in which the equipment can be used without being affected.			
	Non-ME equipment used in an ME system			
	In addition to 16.1 of the general standard: – non-ME equipment used in an ME system shall comply with IEC and ISO EMC standards applicable to that equipment	The HP laptop, model 15-dw3043nq comply with EN 55032 and EN 55035	Р	
,	– non-ME equipment used in an ME system for which the intended EM environment could result in the loss of basic safety or essential performance of the ME system due to the non-ME equipment shall be tested according to the requirements of this collateral standard		NA	
	General test conditions			
4.3.1	Configurations			
	ME equipment and ME systems shall be tested in representative configurations, consistent with intended use, that are most likely to result in unacceptable risk, as determined by the manufacturer.	The equipment was tested in operation conditions, powered via USB port of th laptop, and with the applied parts to patient connected to him.		
	These configurations shall include: – attachment of cables to all ports as necessary to achieve the intended use (including SIP/SOPS and, if applicable, the potential equalization conductor)	The applied parts to patient connected equipment	to P	
	- attachment of all tubing and filling of all fluid containers - termination of the cables with the intended	Not applicable.	NA P	
	equipment, subsystem simulators as specified in 7.1.4 and 8.5, patient physiological simulators as specified in 7.1.9 and 8.2 or artificial hands as specified in 7.1.10 and 8.4			
	– earthing on the enclosure port, if applicable, including connections to the terminal for the connection of a potential equalization conductor	Not applicable.	NA	
	- use of cables and connectors that meet the specifications of the ME equipment or ME system manufacturer		Р	
	Special ME equipment or ME system hardware or software might be needed to perform the tests specified in Clause 7 and Clause 8.	Not applicable.	NA	
4.3.2	Artificial hand			
	If an artificial hand is used, an RC network should be used for each connection to the patient (C = 220 pF \pm 20%; R = 510 Ω \pm 10%), connected to the reference plane.		P	
4.3.3	Power input voltages and frequencies			
Modification If a test is applicable, it shall be performed using the follow power input voltages and frequencies (according to Table 1): The tests were performed with following power supply levels, on the test conditions:		The tests were performed with the following power supply levels, depend on the test conditions: Stabilized DC power supply (5 V _{dc}) via the laptop USB port.		





		Test Report no. 167 / 2023	Page 4/20	
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021	Results	Fulfilling the requiremen	
	Electromagnetic radiation disturbance	,		
	(radiated emissions) (CISPR 11)	0. 1 1 1 1 1 1 1 1 1 1 1 1 1		
	- power input voltage : any one voltage	Stabilized DC power supply (5 V_{dc}) the laptop USB port.		
	- line frequency : any one frequency	-	NA	
	3) Harmonic current emissions (IEC 61000-3-2)	Stabilized DC power supply (5 V_{dc}) the laptop USB port.	/ia NA	
	4) Voltage changes, voltage fluctuations and flicker emissions (IEC 61000-3-3)	Stabilized DC power supply (5 V_{dc}) the laptop USB port.	/ia NA	
	5) Electrostatic discharge immunity (IEC 61000-4-2)			
	- power input voltage : any one voltage Stabilized DC power supply (5 V the laptop USB port.		via P	
	- line frequency : any one frequency	-	NA	
	6) Radiated RF electromagnetic field immunity (IEC 61000-4-3)			
	- power input voltage : any one voltage	Stabilized DC power supply (5 V _{dc}) the laptop USB port.	via P	
	- line frequency : any one frequency	-	NA	
	7) Immunity to proximity fields from RF wireless communications equipment (IEC 61000-4-3) (interim method)			
	- power input voltage : any one voltage	Stabilized DC power supply (5 V _{dc}) the laptop USB port.	via P	
	- line frequency: any one frequency	-	NA	
	8) Electrical fast transient/burst immunity – a.c. mains (IEC 61000-4-4)	Stabilized DC power supply (5 V _{dc}) the laptop USB port.	via NA	
	9) Electrical fast transient/burst immunity – I/O SIP/SOP ports (IEC 61000-4-4)	Without I/O SIP/SOP ports provided with cables longer than 3 m.	I NA	
	10) Surge immunity (IEC 61000-4-5)	Stabilized DC power supply (5 V _{dc}) the laptop USB port.		
	11) Immunity to conducted disturbances induced by RF fields (conducted RF disturbance immunity) – a.c. mains (IEC 61000-4-6)	Stabilized DC power supply (5 V _{dc}) the laptop USB port.	via NA	
	12) Immunity to conducted disturbances induced by RF fields (conducted disturbance immunity) – SIP/SOP ports (IEC 61000-4-6)	Without I/O SIP/SOP ports provided with cables longer than 3 m.	l NA	
	13) Power frequency magnetic field immunity (IEC 61000-4-8)			
	- power input voltage : any one voltage	Stabilized DC power supply (5 V _{dc}) the laptop USB port.		
	 line frequency: 50 Hz or 60 Hz (same with line frequency of the ME equipment or ME system) 	The frequency of the national AC mains supply (50 Hz) was used	Р	
	14) Voltage dips immunity (IEC 61000-4-11)	Stabilized DC power supply (5 V _{dc}) the laptop USB port.		
	15) Voltage short interruptions and voltage variations immunity (IEC 61000-4-11)	Stabilized DC power supply (5 V _{dc}) the laptop USB port.		
	- power input voltage: any one voltage - power input voltage: any one voltage	Not contain magnetically sensitive components or circuitry.	NA	
5	 line frequency : any one frequency ME equipment and ME systems identification 	n marking and documents		
5.1	Additional requirements for marking on the outside of ME equipment and ME systems that are specified for use only in a shielded	n, marking and documents	NA	





	Laboratoral de modrean pentra continuarea i readester Listanes		LICPE	
	Test Report no. 167 / 2023 F		Page 5/20	
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021	Results	Fulfilling the requirement	
5.2	Accompanying documents			
5.2.1	Instructions for use			
5.2.1.1	General			
	In addition to the requirements of 7.9.2 of the			
	general standard, the instructions for use shall			
	include the following:		-t D	
	a) a statement of the environments for which the	Used in medical areas by the therapi	st. P	
	ME equipment or ME system is suitable.	The risk management process specifie	s P	
	b) the performance of the ME equipment or ME system that was determined to be essential	the electromagnetic environment	5	
	performance and a description of what the	conditions in which the equipment can	be	
	operator can expect if the essential performance is			
	lost or degraded due to EM disturbances			
	c) a warning statement to the effect that	Not applicable.	NA	
	"WARNING:			
	Use of this equipment adjacent to or stacked with			
	other equipment should be avoided because it			
	could result in improper operation.			
	If such use is necessary, this equipment and the			
	other equipment should be observed to verify that they are operating normally."			
	d) a list of all cables and maximum lengths of	Not applicable.	NA	
	cables (if applicable), transducers and other	Тчос арриоавіс.		
	accessories that are replaceable by the			
	responsible organization and that are likely to			
	affect compliance of the ME equipment or ME			
	system with the requirements of Clause 7			
	(Emissions) and Clause 8 (Immunity).			
	e) a warning statement to the effect that	The user manual specify that to the	Р	
	"WARNING: Use of accessories, transducers and cables other	equipment is only connected the application parts delivery by the manufacturer and		
	than those specified or provided by the	the suitable USB cables .		
	manufacturer of this equipment could result in	the salable obb capies.		
	increased electromagnetic emissions or			
	decreased electromagnetic immunity of this			
	equipment and result in improper operation."			
	f) a warning statement to the effect that:	The user instructions provide for the use	e of P	
	"WARNING:	portable RF equipment a minimum		
	Portable RF communications equipment should	distance of 30 cm from the equipment		
	be used no closer than 30 cm (12 inches) to any			
	part of the ME equipment or ME system, including cables specified by the manufacturer.			
	Otherwise, degradation of the performance of this			
	equipment could result."			
	To assure the levels of immunity specified in	The test conditions (RF power,	Р	
	Table 9, the test conditions shall be calculated	distance) were calculated with the		
	with the equation specified in 8.10	equation from 8.10.		
5.2.1.2	Requirements applicable to ME equipment and	Not applicable.	NA	
	ME systems classified class A according to			
F 0 0	CISPR 11			
5.2.2	Technical description Requirements applicable to all ME equipments	nt and ME systems		
5.2.2.1	In addition to the requirements of 7.9.3 of the	The user manual specifies the	Р	
	general standard, the technical description shall	electromagnetic environment condition	1	
	describe precautions to be taken to prevent adverse			
	events to the patient and operator due to	without being affected.		
	electromagnetic disturbances			





		Test Report no. 167 / 2023	Page 6/20
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021	Results	Fulfilling the requiremen
	For all ME equipment and ME systems, the technical description shall include the following information: a) the compliance for each emissions and immunity standard or test specified by this collateral standard, e.g. emissions class and	The user manual specify the emissions and immunity standards and the levels used for tests.	
	group and immunity test level; b) any deviations from this collateral standard and allowances used;		NA
	c) all necessary instructions for maintaining basic safety and essential performance with regard to electromagnetic disturbances for the expected service life	The user manual specifies the electromagnetic environment condition in which the equipment can be used without being affected.	P
5.2.2.2	Requirements applicable to ME equipment and ME systems specified for use only in a shielded location special environment	Not applicable.	NA
5.2.2.3	Requirements applicable to ME equipment that intentionally receives RF electromagnetic energy for the purpose of its operation	Not applicable.	NA
5.2.2.4	Requirements applicable to ME equipment that includes RF transmitters	Not applicable.	NA
5.2.2.5	Requirements applicable to permanently installed large ME equipment and large ME systems	Not applicable.	
5.2.2.6	Requirements applicable to ME equipment and ME systems that claim compatibility with HF surgical equipment	Not applicable.	
6	Documentation of the tests		
6.1	General The documentation of the tests shall contain all the information necessary to facilitate dequate planning (test plan) and execution (test report) of the tests so that they can be readily reproduced	e applicable requirements of SR EN 60601-1-2:2016, under the conditions	
6.2	Prior to the start of formal testing, a detailed test plan shall be provided to the test laboratory.	a detailed test The tests were performer according with	
6.3	Test report The test report shall meet the requirements of Clause 9	See this TR.	Р
7	Electromagnetic emissions requirements for I		
7.1	Protection of radio services and other equipment	ent	
7.1.1	General Unless otherwise specified herein, ME equipment and ME systems shall comply with CISPR 11. SR EN 55011:2016 + A1:2017 (CISPR 11). For tests see Annex 1 from this TR.		
7.1.2	Operating modes During emissions testing, the ME equipment or ME system shall be tested in the modes that	The equipment was tested in normal operating mode by used the software installed on the lapton	Р
	maximize emissions In addition to testing for emissions in active modes, inclusion of standby mode should be considered.	installed on the laptop Shortly after attaching the applied parto the patient, the program has been	





Laboratorul de Încercări pentru Certificarea Produselor Electrice

	Test Report no. 167 / 2023 Page			
	Requirement according to Results Full Results			
7.1.3	Multimedia equipment			
	Multimedia equipment connected to ME equipment and ME systems shall comply with CISPR 32. If CISPR 32 class A equipment is supplied as part of an ME system, the ME system shall be	The HP laptop, model 15-dw3043nq comply with EN 55032 (CISPR 32)	P	
	classified class A.			
7.1.4	Subsystems	Not applicable.	NA	
7.1.5	ME equipment and ME systems specified for use only in a shielded location special environment	Not applicable.	NA	
7.1.6	ME equipment and ME systems that include radio equipment	Not applicable.	NA	
7.1.7	ME equipment whose main functions are performed by motors and switching or regulating devices	Not applicable.	NA	
7.1.8	ME equipment and ME systems containing X-ray generators	Not applicable.	NA	
7.1.9	Patient physiological simulation			
	The risks occuring from reasonably foreseeable electromagnetic disturbances must be considered in the risk management process.	The risk management process specification the electromagnetic environment conditions in which the equipment cape used without being affected.		
7.1.10	Artificial hand			
	The risks occuring from reasonably foreseeable electromagnetic disturbances must be considered in the risk management process.	The risk management process specification the electromagnetic environment conditions in which the equipment cape used without being affected.		
7.1.11	Patient-coupled cables	be used without being directed.		
7	Patient-coupled cables shall be considered interconnecting cables in accordance with the requirements of CISPR 11. Applied parts to patient.		Р	
7.1.12 Modification A1	Permanently installed large ME equipment and large ME systems	Not applicable.	NA	
7.2	Protection of the public mains network			
7.2.1	Harmonic distortion	Stabilized DC power supply (5 V _{dc})	via NA	
7.2.2	Voltage fluctuations and flicker	the laptop USB port.		
7.3	Emissions requirements summary			
	The emissions requirements are summarized as follow:			
	Conducted and radiated RF emissions for professional healthcare facility environment: CISPR 11	t: For tests see Annex 1 from this TR.		
	- for home healthcare environment: CISPR 11		via NA	
	2) Harmonic distortion	Stabilized DC power supply (5 V _{dc}) via the laptop USB port.		
	3) Voltage fluctuations and flicker	Stabilized DC power supply (5 V _{dc}) the laptop USB port.	via	
8	Electromagnetic immunity requirements for	IE equipment and ME systems	***************************************	
8.1*	General			
		For tests see Annexs 26 from this TR.	S P	

Ediţia din 12.01.2022 LICPE Cod PG-24-F-27R





Laboratorul de Încercări pentru Certificarea Produselor Electrice

Test Report no. 167 / 2023 Page 8/20

		Test Report no. 167 / 2023	Page 8/20	
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021	Results	Fulfilling the requirement	
	Electromagnetic immunity tests: – shall be performed in a well-defined and reproducible manner		Р	
	 – shall be performed individually as single tests in sequence, and – may be performed in any order 		P	
	At least one of each type of port (e.g. having the same input or output electronic circuits,loads, connected equipment) shall be connected during immunity testing.		P	
	If the ME equipment or ME system has multiple identical ports, it is only necessary to test one of each type during immunity testing		Р	
	For the case in which the ME equipment or ME system is damaged by an immunity test signal, the remainder of the immunity test shall be take account of defect.		NA	
Modification A1	The immunity test requirements shall be applied to the ports of the ME equipment or ME system as specified in Table 4 through Table 9 and Table 11 according to the environments (locations) of intended use.	Used in medical areas environment, the therapist.		
Modification A1	Table 4 through Table 9 and Table 11 specify immunity requirements and test conditions for the professional healthcare facility environment and the home healthcare environment.	Used in medical areas environment, the therapist.	by P	
Modification A1	The procedure specified in Annex E can be used to determine immunity test levels for special environments, or, if justified, can be used to modify the immunity test levels of Table 4 through Table 9 and Table 11, based on specific environmental characteristics or mitigations	Used in medical areas environment, the therapist.	by NA	
Modification A1	For ME equipment and ME systems for which the intended use includes types of transportation (e.g. land, sea and air vehicles) or other locations in the home healthcare environment such as those that can be accessed by walking (e.g. near radiofrequency identification (RFID) systems, antitheft systems), if additional immunity tests or immunity test levels that are higher than those specified in Table 4 through Table 9 and Table 11 are appropriate or are specified by standards applicable to a mode or EM environment of transportation, these additional tests and higher immunity test levels shall apply.	Used in medical areas environment, the therapist.	by NA	
Modification A1		Used in medical areas environment, the therapist	by NA	





Laboratorul de Încercări pentru Certificarea Produselor Electrice Test Report no. 167 / 2023 Page 9/20 Fulfillina Requirement according to Results Clause the SR EN 60601-1-2:2016 + A1:2021 requirement Used in medical areas environment, by If the intended use of the ME equipment or ME system includes more than one environment. the therapist the most stringent immunity test levels among all the applicable environments shall apply The power frequency for all immunity tests may The ME system (for data processing) Modification can be powered by the public AC mains be selected at any one of the nominal power 41 with a frequency of 50 Hz frequencies of the ME equipment or ME system, except as otherwise specified in Table 1 and Table 4 through Table 9 and Table 11 P Before immunity testing begins, the manufacturer shall determine specific, detailed immunity pass/fail criteria. NA Immunity pass/fail criteria may specify degradations that are acceptable because they do not result in unacceptable risk ME equipment and ME systems shall meet the P immunity pass/fail criteria during and after the immunity tests. Patient physiological simulation 8.2 If simulation of the patient is required to verify The RC networks were used to simulate normal operation of the ME equipment or ME the patient. system, it shall be provided during immunity testing. Termination of patient-coupled parts 8.3 For testing according to IEC 61000-4-4 and Provided with terminals for applied parts IEC 61000-4-6, the conditions specified in 4.3.2 to patient. apply. These conditions may also be used in other tests, as specified by the manufacturer Hand-held ME equipment and parts intended Not applicable. NA 8.4 to be hand-held 8.5 Subsystems Not applicable. NA 8.6 Not applicable. NA

Permanently installed large ME equipment Modification and large ME systems A1 **Operating modes** 8.7 During immunity testing, the basic safety and essential performance shall be tested in the modes and settings that are most likely to result in an unacceptable risk, as determined by the manufacturer. This shall be determined using risk analysis, The risk management process specifies P experience, engineering analysis, or pretesting. the electromagnetic environment conditions in which the equipment can be used without being affected. NA If the ME equipment or ME system is not rated for continuous duty, a duty cycle may be selected that is appropriate for the ME equipment or ME system under test. The standby mode should be considered for Shortly after attaching the applied parts NA inclusion in immunity testing, particularly for ME to the patient, the program is run equipment and ME systems that are in standby mode for long periods of time in the presence of patients or operators.

Ediția din 12.01.2022 LICPE Cod PG-24-F-27R





Laboratorul de Încercări pentru Certificarea Produselor Electrice

		Test Report no. 167 / 2023 Page		
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021	Results	Fulfilling the requirement	
8.8	Non-ME equipment			
	ME system shall fulfil the pass/fail criteria and immunity test levels of Clause 8 if it has been determined, as a result of the risk management process, that the non-ME equipment could affect the basic safety or essential performance of the ME system	Stabilized DC power supply (5 V_{dc}) via the laptop USB port. The HP laptop, model 15-dw3043nq comply with EN 55032, EN 55035, EN 61000-3-3 for EMC and for safety requirements with EN 60950-1	P	
8.9	Immunity test levels			
Modification A1	Immunity test levels for basic safety and essential performance of EM equipment and EM systems shall be according to the professional healthcare facility environment, home healthcare environment, and special environment, and specified in Table 4 through Table 9 and 8.11	Used in medical areas environment, by the therapist	y P	
	If applicable, an unknown intended use location shall be assigned to an environment with a similar location, as determined by the manufacturer		NA	
Modification A1	When a manufacturer knows from experience, published data, or representative measurements that the environment of intended use has unique characteristics, he shall take this into consideration in the risk management process.		NA	
	Level for enclosure port (Table 4)			
*	1) Electrostatic discharge (IEC 61000-4-2) - for home healthcare environment • ± 8 kV by contact • ± 2 kV, ± 4 kV, ± 8 kV, ± 15 kV by air	For test see Annex 2 from this TR.	NA	
	 for professional healthcare facility environment ± 8 kV by contact ± 2 kV, ± 4 kV, ± 8 kV, ± 15 kV by air 	± 8 kV (contact) ± 15 kV (air)	P P	
*	2) Radiated RF EM fields (IEC 61000-4-3) - for home healthcare environment: • 10 V/m • 80 MHz – 2,7 GHz • 80 % AM at 1 kHz	For test see Annex 3 from this TR.	NA	
	 for professional healthcare facility environment 3 V/m 80 MHz – 2,7 GHz 80 % AM at 1 kHz 	Field intensity: 3 V/m Frequencies: 80 MHz – 2,7 GHz Modulation signal: 1 kHz Degree of modulation: 80 % AM Vertical and horizontal polarization	P P P	
*	3) Proximity fields from RF wireless communications equipment (IEC 61000-4-3) - for home healthcare environment:	For test see Annex 4 from this TR.	NA	
	• see 8.10		INA	
	for professional healthcare facility environmentsee 8.10	See subclause 8.10 for specific levels each test frequency.	at P	

Ediţia din 12.01.2022 LICPE Cod PG-24-F-27R



LICPE

Test Report no.	. 167 / 2023	Page 11/20
root report no.	101 / 2020	I age I

		Test Report no. 167 / 2023	Page 11/2	
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021	Results	Fulfilling the requiremen	
Replace A1	4) Rated power frequency magnetic fields (IEC 61000-4-8)	For test see Annex 5 from this TR.		
	 for home healthcare environment: 30 A/m 50 Hz or 60 Hz 		NA	
	 for professional healthcare facility environment 30 A/m 50 Hz or 60 Hz 	Field intensity : 30 A/m 50 Hz	P	
Addition A1	5) Proximity magnetic fields (IEC 61000-4-39) • see 8.11	Not contain magnetically sensitive components or circuitry.	NA	
Modification A1	Level for input a.c. power port (Table 5)	Stabilized DC power supply (5 V _{dc}) the laptop USB port.	via NA	
	Level for input d.c. power port (Table 6)			
	1) Electrical fast transients/bursts (IEC 61000-4-4)	Stabilized DC power supply (5 V _{dc}) the laptop USB port, with a detachable cable less than 3 m long		
	2) Surges (line-to-line) (IEC 61000-4-5)	Stabilized DC power supply (5 V _{dc}) via the laptop USB port, with a detachable cable less than 3 m long		
	3) Surges (line-to-ground) (IEC 61000-4-5)	Without protective earthing circuits.		
	4) Conducted disturbances induced by RF fields (IEC 61000-4-6)	Stabilized DC power supply (5 V _{dc}) the laptop USB port, with a detachable cable less than 3 m long		
	Electrical transient conduction along supply are supply as (ISO 7637-2) The equipment is not intended for installation and use on vehicles.		NA	
	Level for patient coupling port (Table 7)			
*	1) Electrostatic discharge (IEC 61000-4-2)	For test see Annex 2 from this TR.		
	- for home healthcare environment •± 8 kV by contact •± 2 kV, ± 4 kV, ± 8 kV, ± 15 kV by air	To the top of the top	NA	
	- for professional healthcare facility environment			
	 ± 8 kV by contact ± 2 kV, ± 4 kV, ± 8 kV, ± 15 kV by air 	± 8 kV (contact) ± 15 kV (air)	P	
*	2) Conducted disturbances induced by RF fields (IEC 61000-4-6)	± 15 kV (air) For tests see Annex 6 from this TR.		
	 for home healthcare environment: 3 V 6 V in ISM bands (6,765 MHz to 6,795 MHz; 13,553 MHz to 13,567 MHz; 26,957 MHz to 27,283 MHz; and 40,66 MHz to 40,70 MHz) 6 V in amateur radio bands (1,8 MHz to 2,0 MHz, 3,5 MHz to 4,0 MHz, 5,3 MHz to 5,4 MHz, 7 MHz to 7,3 MHz, 		NA	
	10,1 MHz to 10,15 MHz, 14 MHz to 14,2 MHz, 18,07 MHz to 18,17 MHz, 21,0 MHz to 21,4 MHz, 24,89 MHz to 24,99 MHz, 28,0 MHz to 29,7 MHz and 50,0 MHz to 54,0 MHz) • 0,15 MHz – 80 MHz • 80 % AM at 1 kHz			





Laboratorul de Încercări pentru Certificarea Produselor Electrice

Test Report no. 167 / 2023 Page 12/20

		Test Report no. 167 / 2023	Page 12/2	
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021	Results	Fulfilling the requiremen	
	- for professional healthcare facility environment		Toquii orrio	
	3 V	U _{test} = 3 V, for 0,15 MHz - 80 MHz frequency range, except ISM bands (see 8.1 from this TR for used U _{test} = V, for amateur radio bands)		
	• 6 V in ISM bands (6,765 MHz to 6,795 MHz; 13,553 MHz to 13,567 MHz; 26,957 MHz to 27,283 MHz; and 40,66 MHz to 40,70 MHz)			
	• 6 V in amateur radio bands (1,8 MHz to 2,0 MHz, 3,5 MHz to 4,0 MHz, 5,3 MHz to 5,4 MHz, 7 MHz to 7,3 MHz, 10,1 MHz to 10,15 MHz, 14 MHz to 14,2 MHz, 18,07 MHz to 18,17 MHz, 21,0 MHz to 21,4 MHz, 24,89 MHz to 24,99 MHz, 28,0 MHz to 29,7 MHz and 50,0 MHz to 54,0 MHz)		IHz, z, z, to	
	0,15 MHz - 80 MHz 80 % AM at 1 kHz	Frequencies: 0,15 MHz – 80 MHz Modulation signal: 1 kHz Degree of modulation: 80 % AM	P P	
	(Table 8)			
	1) Electrostatic discharge (IEC 61000-4-2)	For test see Annex 2 from this TR.		
	- for home healthcare environment •± 8 kV by contact •± 2 kV, ± 4 kV, ± 8 kV, ± 15 kV by air		NA	
	 for professional healthcare facility environment ± 8 kV by contact ± 2 kV, ± 4 kV, ± 8 kV, ± 15 kV by air 	± 8 kV (contact) ± 15 kV (air)	P	
	2) Electrical fast transients/bursts (IEC 61000-4-4) - for home healthcare environment • ± 1 kV • 100 kHz repetition frequency	Without SIP/SOP I/O ports provided w a cables longer than 3 m		
	 for professional healthcare facility environment ± 1 kV 100 kHz repetition frequency 3) Surges (line-to-ground) (IEC 61000-4-5) 	Class II equipment	NA	
	 for home healthcare environment ± 2 kV for professional healthcare facility environment ± 2 kV 			
	4) Conducted disturbances induced by RF fields (IEC 61000-4-6)	Without SIP/SOP I/O ports provided was a cables longer than 3 m	ith NA	
8.10	Immunity to proximity fields from RF wireles	s communications equipment	, , , , , , ,	
	The enclosure port of ME equipment and ME systems shall be tested as specified in Table 9 using the test methods specified in IEC 61000-4-3.	The tests were performed using the temethods specified in SR EN 61000-4 and levels specified in Table 9 from SR EN 60601-1-2:2016	-3	
Replace A1	Test specifications for enclosure port immunity to RF wireless communications equipment (Table 9)	For tests see Annex 6 from this TR, with modifications specified at 5.2.1 and 8.6.		
	Test frequency: 385 MHz (Band 380 MHz – 390 MHz) • Modulation: pulse modulation 18 Hz • Maxim power: 1,8 W • Distance: 0.3 m • Level: 27 V/m	The test frequency (385 MHz) was appl with following conditions: - with 18 Hz pulse modulation - 1 W RF output power - 0.22 m distance to equipment - the achieved level of immunity: 27 V/n		



Laboratorul de Încercări pentru Certificarea Produselor Electrice

		Test Report no. 167 / 2023	Page 13/20
Clause	Requirement according to SR EN 60601-1-2:2016 + A1:2021 Results		Fulfilling the requiremen
	Test frequency: 450 MHz (Band 430 MHz – 470 MHz) • Modulation: frequency modulation ± 5 kHz deviation; 1 kHz sine • Maxim power: 2 W • Distance: 0.3 m • Level: 28 V/m	The test frequency (450 MHz) was applied with following conditions: - with 1 kHz modulation signal and frequency modulation with ± 5 kHz deviation 1 W RF output power - 0.21 m distance to equipment - the achieved level of immunity: 28 V/m	
	Test frequency: 710 MHz; 745 MHz; 780 MHz (Band 704 MHz – 787 MHz) • Modulation: pulse modulation 217 Hz • Maxim power: 0.2 W • Distance: 0.3 m • Level: 9 V/m	780 MHz) were applied with following conditions:	
	Test frequency: 810 MHz; 870 MHz; 930 MHz (Band 800 MHz – 960 MHz) • Modulation: pulse modulation 18 Hz • Maxim power: 2 W • Distance: 0.3 m • Level: 28 V/m	The test frequencies (810 MHz; 870 MHz; 930 MHz) were applied with following conditions: - with 18 Hz pulse modulation - 1 W RF output power - 0.21 m distance to equipment - the achieved level of immunity: 28 V/m	Р
	Test frequency: 1720 MHz; 1845 MHz; 1970 MHz (Band 1700 MHz – 1990 MHz) • Modulation: pulse modulation 217 Hz • Maxim power: 2 W • Distance: 0.3 m • Level: 28 V/m	345 MHz; 1970 MHz The test frequencies (720 MHz; 1845 MHz; 1970 MHz) were applied with following conditions:	
	Test frequency: 2450 MHz (Band 2400 MHz – 2570 MHz) • Modulation: pulse modulation 217 Hz • Maxim power: 2 W • Distance: 0.3 m • Level: 28 V/m	The test frequency (2450 MHz) was applied with following conditions: - with 217 Hz pulse modulation - 2 W RF output power - 0.3 m distance to equipment - the achieved level of immunity: 28 V/m	ed P
8.11 Addition A1	Immunity to proximity fields in the frequency range 9 kHz to 13,56 MHz	Not contain magnetically sensitive components or circuitry.	

Fulfilling the requirement:

P - The requirement is met (PASS)

NA - The requirement is not applicable to this product type (NOT APPLICABLE)

NOTE: The tests marked with (*) are not covered by the RENAR accreditation but have been performed in accordance with the requirements of SR EN ISO/IEC 17025 and comply with applicable LICPE documents and RENAR policies and regulations.

For information about accredited tests, please refer to the Accreditation Certificate LI 911 and Annex 1 to the Accreditation Certificate LI 911 on site www.oicpe.ro

LICPE Cod PG-24-F-27R Ediţia din 12.01.2022



Laboratorul de Încercări pentru Certificarea Produselor Electrice



Test Report no. 167 / 2023

Page 14/20

Clause

Requirement according to SR EN 60601-1-2:2016 + A1:2021

Results

Fulfilling the requirement

Anexa 1 - Emisii RF conduse (Perturbaţii electromagnetice radiate)

Test according to the requirements of subclauses 7.1.1 and 7.3 from this TR.

Power supply according to subclause 4.3.3 from this TR.

Test method according to SR EN 55011:2016 + A1:2017+A11:2020+A2:2021, clause 7 and clause 8 (subclause 8.3).

Allowable limits according to SR EN 55011:2016 + A1:2017+A11:2020+A2:2021, clause 6 (subclause 6.2.1, table 7).

Used apparatus according to Annex 7 to this TR.

Ambient RF emissions was measured for the 30 MHz... 1000 MHz ranges, for horizontal and vertical polarization (Figure 1, Figure 2).

Measurements were resumed under normal operating conditions (Figure 3, Figure 4).

Note: Because the measurement was made in the electromagnetic free space (open area test site), signals for 88-108 MHz and 174-182 MHz (terrestrial transmissions), 390 MHz (data transmission), 420-460 MHz (mobile telephony), 730-790 MHz (terrestrial digital television) and 920-960 MHz (GSM mobile telephony) ranges, will not be considered.

1) 30 MHz ÷ 1000 MHz range ambient RF emissions, horizontal polarization




				Figure
	ED1	T PEAK LIST (Fina	al Measurement Re	CONTRACTOR AND PROPERTY AND PRO
Tra	cel:	B4-57		
Tra	ice2:			
Tra	ice3:			
	TRACE	FREQUENCY	LEVEL dBµV	DELTA LIMIT dB
1	Quasi Peak	88.48 MHz	47.09 L1	-2.90
1	Quasi Peak	89.04 MHz	53.66 L1	3.66
1	Quasi Peak	90.84 MHz	50.25 L1	0.25
1	Quasi Peak	92.08 MHz	43.01 L1	-6.98
1	Quasi Peak	96.12 MHz	54.74 L1	4.74
1	Quasi Peak	99.32 MHz	49.60 L1	-0.39
1	Quasi Peak	100.6 MHz	51.74 L1	1.74
1	Quasi Peak	101.84 MHz	50.84 L1	0.84
1	Quasi Peak	102.72 MHz	54.20 L1	4.20
1	Quasi Peak	103.84 MHz	52.25 L1	2.25
1	Quasi Peak	105.8 MHz	48.43 Ll	-1.56
1	Quasi Peak	106.16 MHz	37.36 L1	-12.63
1	Quasi Peak	394 MHz	39.06 L1	-17.93
1	Quasi Peak	543.8 MHz	40.90 L1	-16.09
1	Quasi Peak	545.04 MHz	42.91 L1	-14.08
1	Quasi Peak	546.88 MHz	43.88 L1	-13.11
1	Quasi Peak	548.72 MHz	35.42 L1	-21.57
1	Quasi Peak	791.68 MHz	43.92 L1	-13.07
1	Quasi Peak	791.96 MHz	44.04 L1	-12.95
1	Quasi Peak	793.36 MHz	46.54 L1	-10.45

LICPE Cod PG-24-F-27R Ediţia din 12.01.2022



Laboratorul de Încercări pentru Certificarea Produselor Electrice



Tost Poport no. 167 / 2022

Test Report no. 167 / 2023


Page 15/20

Clause

Requirement according to SR EN 60601-1-2:2016 + A1:2021

Results


Fulfilling the requirement




2) 30 MHz ÷ 1000 MHz range ambient RF emissions, vertical polarization



Demod AM Att 10 dB RBW 120 kHz MT 1 s PREAMP OFF







Laboratorul de Încercări pentru Certificarea Produselor Electrice



Test Report no. 167 / 2023


Page 16/20

Clause


Requirement according to SR EN 60601-1-2:2016 + A1:2021

Results


Fulfilling the requirement



Tra	cel:	B4-57					
Tra	ce2:						
Tra	ce3:						
	TRACE	FREQUENCY	LEVEL dBuV	DELTA LIMIT dB			
1	Quasi Peak	931.6 MHz	48.90 L1	-8.09			
1	Quasi Peak	935.92 MHz	46.72 L1	-10.27			
1	Quasi Peak	936.44 MHz	41.58 L1	-15.41			
1	Quasi Peak	937.52 MHz	37.51 L1	-19.48			
1	Quasi Peak	937.8 MHz	43.79 L1	-13.20			
1	Quasi Peak	938.04 MHz	43.00 L1	-13.99			
1	Quasi Peak	938.28 MHz	38.36 L1	-18.63			
1	Quasi Peak	938.48 MHz	40.08 L1	-16.91			
1	Quasi Peak	938.64 MHz	39.68 L1	-17.31			
1	Quasi Peak	938.92 MHz	37.23 L1	-19.77			
1	Quasi Peak	939.4 MHz	46.70 L1	-10.29			
1	Quasi Peak	942.16 MHz	41.14 L1	-15.85			
1	Quasi Peak	942.32 MHz	40.75 L1	-16.24			
1	Quasi Peak	945.88 MHz	44.50 L1	-12.49			
1	Quasi Peak	946.84 MHz	40.64 1.1	-16.35			
1	Quasi Peak	948.24 MHz	42.18 L1	-14.82			
1	Quasi Peak	948.36 MHz	45.20 L1	-11.79			
1	Quasi Peak	948.52 MHz	43.26 L1	-13.74			
1	Quasi Peak	956.24 MHz	40.19 L1	-16.80			
1	Quasi Peak	959.88 MHz	49.84 L1	-7.15			



3) 30 MHz ÷ 1000 MHz range RF emissions, horizontal polarization, operational






Figure 3



Laboratorul de Încercări pentru Certificarea Produselor Electrice



Test Report no. 167 / 2023


Page 17/20


Clause

Requirement according to SR EN 60601-1-2:2016 + A1:2021


Results

Fulfilling the requirement





4) 30 MHz ÷ 1000 MHz range RF emissions, vertical polarization, operational



LICPE Cod PG-24-F-27R Ediţia din 12.01.2022

Figure 4



Laboratorul de Încercări pentru Certificarea Produselor Electrice

LICPE

Test Report no. 167 / 2023

Page 18/20


Clause

Requirement according to SR EN 60601-1-2:2016 + A1:2021

Results

Fulfilling the requirement

Tracel: B4-57			Tracel:	B4-57			
Trace2:				Trace2: Trace3:			
Prace3:	FREQUENCY LEVEL dBuV DELTA LIMIT dB		FREQUENCY		LEVEL dBuV	DELTA LIMIT d	
TRACE	FREQUENCY	LEVEL dBuV			548.76 MHz	45.78 L1	-11.21
1 Quasi Peak	89.04 MHz	54.90 L1	4.90	1 Quasi Peak	DESCRIPTION OF THE PROPERTY OF		
1 Quasi Peak	89.44 MHz	43.84 L1	-6.15	1 Quasi Peak	792.32 MHz	48.83 L1	-8.16
1 Quasi Peak	90.72 MHz	51.64 L1	1.64	1 Quasi Peak	795.04 MHz	43.02 L1	-13.98
1 Quasi Peak	96.12 MHz	53.23 L1	3.23	1 Quasi Peak	796.28 MHz	41.13 L1	-15.86
1 Quasi Peak	99.32 MHz	56.60 L1	6.60	1 Quasi Peak	798.04 MHz	37.34 L1	-19.65
1 Quasi Peak	100.24 MHz	45.49 L1	-4.50	1 Quasi Peak	894.4 MHz	35.57 L1	-21.42
1 Ouasi Peak	100.64 MHz	60.56 L1	10.56	1 Quasi Peak	895.68 MHz	35.62 L1	-21.37
1 Quasi Peak	101.32 MHz	43.58 L1	-6.41	1 Quasi Peak	896 MHz	35.70 L1	-21.30
1 Ouasi Peak	101.88 MHz	60.18 L1	10.18	1 Quasi Peak	896.6 MHz	35.66 L1	-21.33
1 Quasi Peak	102.84 MHz	63.37 L1	13.37	1 Quasi Peak	897.2 MHz	35.63 L1	-21.37
1 Ouasi Peak	103.8 MHz	51.73 L1	1.73	1 Quasi Peak	897.56 MHz	35.66 L1	-21.33
1 Quasi Peak	105.8 MHz	60.20 L1	10.20	1 Quasi Peak	907.4 MHz	36.38 L1	-20.61
1 Ouasi Peak	106.2 MHz	47.61 L1	-2.38	1 Quasi Peak	907.56 MHz	37.78 L1	-19.21
1 Quasi Peak	390.4 MHz	45.31 L1	-11.68	1 Quasi Peak	907.72 MH2	41.33 L1	-15.67
1 Quasi Peak	390.68 MHz	44.29 L1	-12.70	1 Quasi Peak	910.32 MHz	78.83 L1	21.83
1 Quasi Peak	392.48 MHz	46.58 L1	-10.41	1 Quasi Peak	912.48 MHz	75.72 L1	18.72
1 Quasi Peak	392.68 MHz	45.91 L1	-11.08	1 Quasi Peak	914.84 MHz	37.29 L1	-19.70
1 Quasi Peak		47.26 L1	-9.73	1 Quasi Peak	914.92 MHz	44.08 L1	-12.91
1 Ouasi Peak		44.48 L1	-12.52	1 Quasi Peak	915.08 MH2	48.81 L1	-8.18
1 Ouasi Peak		40.05 L1	-16.94	1 Quasi Peak	926.44 MHz	49.48 L1	-7.51



 $0 dB (\mu V/m) = 1 \mu V/m$

The requirement is fulfilled

Annex 2 - Electrostatic discharge

Test according to the requirements of :

- a) subclause 8.9 (table 4 for equipment enclosure)
- b) subclause 8.9 (table 7 for patient connections)
- c) subclause 8.9 (table 8 for comunication connection with laptop, which also contains the power supply circuit)

Power supply according to subclause 4.3.3 from this TR.

Test method according to SR EN 61000-4-2:2009, clause 8.

Used apparatus according to Annex 7 to this TR

- During application of electrostatic discharge through contact and air to the equipment enclosure, the equipment was normal operation.
- b) During application of electrostatic discharge through contact and air to the equipment connectors for applied parts and on cables for connection to the patient (without simulation of the patient / artificial hand), the equipment was normal operation.
- c) During application of electrostatic discharge through contact and air to the equipment USB connector for communication with the laptop and the power supply of the equipment, the equipment was normal operation

After the test, the operation of the equipment were checked. Without errors.

The requirement is fulfilled

LICPE Cod PG-24-F-27R Ediția din 12.01.2022



Laboratorul de Încercări pentru Certificarea Produselor Electrice



Test Report no. 167 / 2023

Page 19/20

Clause

Requirement according to SR EN 60601-1-2:2016 + A1:2021

Results

Fulfilling the requirement

Annex 3 - Radiated RF electromagnetic fields

Test according to the requirements of subclause 8.9 (table 4) from this TR.

Power supply according to subclause 4.3.3 from this TR.

Test method according to SR EN 61000-4-3:2020, clause 8.

Used apparatus according to Annex 7 to this TR.

During application of the RF electromagnetic field with vertical and horizontal polarization, through a TEM open coplanare line, to the equipment, the equipment was normal operation.

After the test, the operation of the equipment were checked.

Without errors.

The requirement is fulfilled

Annex 4 - Proximity fields from RF wireless communications equipment

Test according to the requirements of subclause 8.9 (table 4) and subclause 8.10 (table 9) from this TR Power supply according to subclause 4.3.3 from this TR.

Test method according to SR EN 61000-4-3:2006 + A1:2008 + A2:2011, clause 8.

Used apparatus according to Annex 7 to this TR

During application of the RF electromagnetic field with fixed test frequencies, through type λ / 2 antennas, to the equipment, the equipment was normal operation.

After the test, the operation of the equipment were checked.

Without errors.

The requirement is fulfilled

Annex 5 - Rated power frequency magnetic fields

Test according to the requirements of subclause 8.9 (table 4) from this TR.

Power supply according to subclause 4.3.3 from this TR.

Test method according to SR EN 61000-4-8:2010, clause 8.

Used apparatus according to Annex 7 to this TR

During application of the magnetic field at industrial frequency to the distribution head enclosure, the equipment was normal operation.

After the test, the operation of the equipment were checked.

Without errors.

The requirement is fulfilled

Annex 6 - Conducted disturbances induced by RF fields

Test according to the requirements of subclause 8.9 (table 7) from this TR.

Power supply according to subclause 4.3.3 from this TR.

Test method according to SR EN 61000-4-6:2014, clause 7.

Used apparatus according to Annex 7 to this TR

During application of conducted disturbances induced by RF fields , for each frequency range and its appropriate level, the equipment was normal operation.

After the test, the operation of the equipment were checked. Without errors.

The requirement is fulfilled

LICPE Cod PG-24-F-27R Ediţia din 12.01.2022



Laboratorul de Încercări pentru Certificarea Produselor Electrice

LICPE

Test Report no. 167 / 2023

Page 20/20

Clause

Requirement according to SR EN 60601-1-2:2016 + A1:2021

Results

Fulfilling the requirement

Annex 7 - THE LIST OF USED MEASUREMENT AND TEST EQUIPMENTS

Nr.	Denumire încercare	Aparatul de măsură /tip /	Certificat de etalonare /	Incertitudini
crt.		serie sau inventar	emitent	
1	Radiated RF	Test receiver (selective µV-meter for	0001-3005589099/ 18.02.2021/	Laborator:
	emissions	9 kHz3 GHz) type ESCI-3, serial 100611	Rohde &Schwarz	9,4 dB
		Biconic logperiodical antenna HL-562	4041.3000.02/29.03. 2019/	
		Rohde & Schwarz serial 100374	Rohde &Schwarz	
2	Electrostatic	Electrostatic discharge generator	CR32293B / 04.2022	11,7 %
	discharges	Type DITO, serial CRO8423B		
3	Radiated RF EM	Generator RF 250 kHz- 40 GHz,	-	1,6 dB
	fields	type G8257D, Serial MY45141301		
		RF amplifier 0,1 MHz 1 GHz	-	
		type 1W1000A, serial 21856		
		Amplifier RF 1 GHz - 18 GHz	-	
		type ST181-50, serial S1772-1014		
		TEM open line with parallel plates	-	
		type L-TEM-P, unique		
4	Proximity fields	Generator RF 250 kHz- 40 GHz,	-	2 %
	from RF wireless	type G8257D, Serial MY45141301		
	communications	RF amplifier 0,1 MHz 1 GHz	-	
	equipment	type 1W1000A, serial 21856		
		Amplifier RF 1 GHz - 18 GHz	-	
		type ST181-50, serial S1772-1014		
		Antennes type $\lambda/2$ (table 9), uniques.	-	0.0/
5	Rated power	Powermeter type Fluke 39, serial 6417029	1154/20.04.2021 / ARC	9 %
	frequency	Current clamp type Fluke 80i-110s,	BRAŞOV (LE 031)	
	magnetic fields	serial 6417029	00.05.404/04.00.0000	2 40
6	Conducted	Generator RF 9 kHz1 GHz, type SML-01,	03.05-131/24.08.2020	3 dB
	disturbances	serial 102763	INM	
	induced by RF	RF amplifier 0,1 MHz1 GHz	-	
	fields	type 1W1000A, serial 21856		
		Coupling/decoupling RF voltage network	BV 35 20.08.2020	
		type CD –RF unique		
-	Environment	Electronic hygrometer HTC-2	CE 23885-11.22 /	2 %
	conditions	Serial M200545	METROMAT (LE 008)	

Note: Uncertainty is attributed to the expanded uncertainty obtained by multiplying the standard uncertainty with expansion factor k = 2, and was estimated in accordance with SR ISO / IEC Guide 98-3: 2010. Measurand value is within the range designated with a probability of 95.45%

Ediţia din 12.01.2022